

Certificate of Compliance

Certificate Number:

UL-US-2325753-1

Report Reference:

EX15566-20111026

Issue Date:

2024-05-06

Issued to:

FIRE EATER A/S
Voelundsvej 17 Hillerod 3400
Denmark

This certificate confirms that representative samples of:
GAQF - Clean-agent Extinguishing System Units
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL/ULC 2127, Edition: 4, Issue Date: 2024-3-14

Additional Information:
See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2325753-1
Report reference EX15566-20111026
Date 2024-05-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

| Model | Product Description |
|--|-----------------------|
| IG-541 (Inergen) engineered extinguishing system units, 2900 or 4350 psig (200 or 300 bar) | Engineered, Inert Gas |

| Clean Agent Extinguishing System Units | Value | |
|--|-------------------------------|-------------------------------|
| Extinguishing Agent (ASHRAE Designation) | IG-541 | |
| Manuals and Bulletins | | |
| Part No. | Description | Date/Rev |
| CI UL Manual | Installation Manual | 2024-03-25 |
| System Unit Information | | |
| Operating Pressure at Temperature | Minimum Operating Temperature | Maximum Operating Temperature |
| 200 bar (2900 psig) @ 21°C | 32 F (0 C) | 150 F (65.6 C) |
| 300 bar (4350 psig) @ 21°C | 32 F (0 C) | 150 F (65.6 C) |
| These installations require the use of the Listee's flow calculation software: | | |
| IMT V3.0 | | |



David Piecuch
 UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number:

ULC-24-000115-0

Report Reference:

EX15566-20111026

Issue Date:

2024-05-06

Issued to:

This certificate confirms that representative samples of:

GAQF7 - Clean-agent Extinguishing System Units Certified for Canada

See Addendum Page for Product Designation(s).

UL/ULC 2127, Edition: 4, Issue Date: 2024-3-14

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number ULC-24-000115-0
Report reference EX15566-20111026
Date 2024-05-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

| Model | Product Description |
|--|-----------------------|
| IG-541 (Inergen) engineered extinguishing system units, 2900 or 4350 psig (200 or 300 bar) | Engineered, Inert Gas |

| Clean Agent Extinguishing System Units | Value | |
|--|-------------------------------|-------------------------------|
| Extinguishing Agent (ASHRAE Designation) | IG-541 | |
| Manuals and Bulletins | | |
| Part No. | Description | Date/Rev |
| CI UL Manual | Installation Manual | 2024-03-25 |
| System Unit Information | | |
| Operating Pressure at Temperature | Minimum Operating Temperature | Maximum Operating Temperature |
| 200 bar (2900 psig) @ 21°C | 32 F (0 C) | 150 F (65.6 C) |
| 300 bar (4350 psig) @ 21°C | 32 F (0 C) | 150 F (65.6 C) |
| These installations require the use of the Listee's flow calculation software: | | |
| IMT V3.0 | | |



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

